



**Type CLE-PT (Non-Indicating) Current Limiting Power Fuses**

Total clearing time-current characteristics, 2.0 Kv to 5.5 Kv

Curves are based on tests starting with fuse units at an ambient temperature of 25°C and without initial load. Curves are plotted to maximum test points so variations should be negative.

**Westinghouse Electric Corporation**  
Switchgear Division, Power Switching Equipment, East Pittsburgh, Pa.  
Printed in USA

Curve No.

**40**

Supersedes Curve No. 40, dated November, 1966

Reference No. 598837

May, 1968